

All communications to be addressed to:

Headquarters
4 Murray Rose Ave
Sydney Olympic Park NSW 2127

Telephone: 1300 NSW RFS
e-mail: records@rfs.nsw.gov.au

Headquarters
Locked Bag 17
Granville NSW 2142

Facsimile: 8741 5433



The Secretary
Department of Planning and Environment (Alpine Resorts)
PO Box 36
Jindabyne NSW 2627

Your Ref: 9709 (EF18/45639)
Our Ref: D18/8111
DA18111616092 BB

ATTENTION: Mark Brown

6 March 2019

Dear Sir / Madam

Integrated Development Application - 24//756705 Stillwell Hotel, Charlotte Pass Village

I refer to your correspondence dated 11 February 2019 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the 'Environmental Planning and Assessment Act 1979', and a Bush Fire Safety Authority, under Section 100B of the 'Rural Fires Act 1997', are now issued subject to the following conditions:

Asset Protection Zones

The intent of measures is to provide sufficient space and maintain reduced fuel loads so as to ensure radiant heat levels of buildings are below critical limits and to prevent direct flame contact with a building. To achieve this, the following conditions shall apply:

1. At the commencement of building works, and in perpetuity, all land within the subject leasehold site shall be managed as an Inner Protection Area (IPA) as outlined within section 4.1.3 and Appendix 5 of 'Planning for Bush Fire Protection 2006' and the NSW Rural Fire Service's document 'Standards for asset protection zones'.

Water and Utilities

The intent of measures is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building. To achieve this, the following conditions shall apply:

2. The provision of all new, and the modification of any existing water, electricity, and gas services shall comply with section 4.1.3 of 'Planning for Bush Fire Protection 2006'.

Evacuation and Emergency Management

The intent of measures is to provide suitable emergency and evacuation (and relocation) arrangements for occupants of special fire protection purpose developments. To achieve this, the following conditions shall apply:

3. Arrangements for emergency and evacuation are to comply with section 4.2.7 of 'Planning for Bush Fire Protection 2006'.
 - An Emergency/Evacuation Plan is to be prepared in accordance with the NSW Rural Fire Service Guidelines for the Preparation of Emergency/Evacuation Plan and comply with Australian Standard AS 3745:2010 'Planning for Emergencies in Facilities'.
 - Detailed plans of all Emergency Assembly Areas including "on site" and "off site" arrangements as stated in Australian Standard AS 3745:2010 'Planning for Emergencies in Facilities' are clearly displayed, and an annual (as a minimum) trial emergency evacuation is conducted.

Design and Construction

The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:

4. All new construction associated with the proposed airlocks shall comply with section 3 and section 7 (BAL 29) Australian Standard AS3959-2009 'Construction of buildings in bush fire-prone areas' or NASH Standard (1.7.14 updated) 'National Standard Steel Framed Construction in Bushfire Areas – 2014' as appropriate and section A3.7 Addendum Appendix 3 of 'Planning for Bush Fire Protection 2006'.
5. The proposed repair and placement works situated on level 5 shall:
 - Not comprise the making of, or an alteration to the size of, any opening in a wall or roof, such as a doorway, window or skylight;
 - Be adequately sealed or protected to prevent the entry of embers; and
 - Use equivalent or improved fire resistant materials that do not affect any existing fire resisting components of the building.
6. The existing building is required to be upgraded to improve ember protection (if not already constructed to the relevant Bushfire Attack Level under AS3959).
 - This can be achieved by undertaking some or all of the following; enclosing all openings (excluding roof tile spaces) or covering openings with a noncorrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any subfloor areas, openable windows, vents, weep holes and eaves. External doors are to be fitted with draft excluders.
 - Details of the proposed upgrades to improve ember protection shall be submitted with the application for the Construction Certificate.

Landscaping

7. All landscaping within the subject site shall comply with the principles of Appendix 5 of 'Planning for Bush Fire Protection 2006'.

This letter is in response to a further assessment of the application submitted and supersedes our previous general terms of approval dated 6 December 2018.

Should you wish to discuss this matter please contact Bradley Bourke on 1300 NSW RFS.

Yours sincerely

A handwritten signature in dark ink, appearing to read 'M. Dotter', with a stylized, flowing script.

Martha Dotter

Acting Team Leader, Development Assessment and Planning

For general information on bush fire protection please visit www.rfs.nsw.gov.au