

Dept. Of Planning - Alpine PO Box 36 Jindabyne NSW 2627

Your reference: (CNR-6080) DA 10181

Our reference: DA20200401001174-Original-1

ATTENTION: Robin Ward Date: Tuesday 21 April 2020

Dear Sir/Madam,

Integrated Development Application s100B - SFPP - Other Tourist Accommodation 7B Diggings Tce Thredbo NSW 2627 AUS, 765//DP1119757

I refer to your correspondence dated 31/03/2020 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

Asset Protection Zones

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:

[APZ 1.0]

At the commencement of building works, and in perpetuity, all land within the subject leasehold site shall be managed as an inner protection area (IPA) in accordance with Appendix 4 of 'Planning for Bush Fire Protection 2019'. When establishing and maintaining an IPA, the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang buildings;
- lower limbs should be removed up to a height of 2 metres above the ground;
- tree canopies should be separated by 2 to 5 metres;
- preference should be given to smooth-barked and evergreen trees;
- large discontinuities or gaps should be provided in the vegetation to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% of ground cover;

1

- clumps of shrubs should be separated from exposed windows and doors by a distance at least twice the height of the vegetation.
- grass should be kept mown (as a guide, grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

Construction Standards

The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:

[D&C 1.0]

New construction shall comply with Sections 3 and 8 (BAL 40) Australian Standard AS3959-2018 Construction of buildings in bush fire-prone areas or NASH Standard (1.7.14 updated) National Standard Steel Framed Construction in Bushfire Areas – 2014 as appropriate and Section 7.5 of 'Planning for Bush Fire Protection 2019'.

[D&C 1.1]

The existing building is required to be upgraded to improve ember protection (if not already constructed to the relevant Bushfire Attack Level under Australian Standard AS3959). This can be achieved by undertaking some, or all of the following; enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any subfloor areas, openable windows, vents, weep holes and eaves. External doors are to be fitted with draft excluders. Details of proposed upgrades to improve ember protection shall be submitted with the application for the Construction Certificate.

Water and Utility Services

The intent of measures is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building. To achieve this, the following conditions shall apply:

[W&U 4.0]

The provision of all new and the modification of any existing water, electricity, and gas services shall comply with Table 7.4a of 'Planning for Bush Fire Protection 2019'.

Landscaping Assessment

The intent of measures is for landscaping. To achieve this, the following conditions shall apply:

[L 1.0]

All landscaping within the subject leasehold site shall comply with the following in accordance with Table 7.4a of 'Planning for Bush Fire Protection 2019':

- compliance with Appendix 4 of Planning for Bush Fire Protection 2019;
- a clear area of low-cut lawn or pavement is maintained adjacent to the house;
- fencing is constructed in accordance with section 7.6; and
- trees and shrubs are located so that:
- the branches will not overhang the roof;
- the tree canopy is not continuous; and
- any proposed windbreak is located on the elevation from which fires are likely to approach.

Emergency and Evacuation Planning Assessment

The intent of measures is to provide suitable emergency and evacuation (and relocation) arrangements for occupants of special fire protection purpose developments. To achieve this, the following conditions shall apply:

[E&E 1.0]

An Emergency/Evacuation Plan shall be prepared in accordance with the NSW Rural Fire Service Guidelines for the 'Preparation of Emergency/Evacuation Plan' and comply with Australian Standard AS 3745:2010 'Planning for Emergencies in Facilities'. Detailed plans of all Emergency Assembly Areas including "on-site" and "off-site" arrangements as stated in Australian Standard AS 3745:2010 'Planning for Emergencies in Facilities' are displayed, and an annual (as a minimum) trial emergency evacuation is conducted.

For any queries regarding this correspondence, please contact Bradley Bourke on 1300 NSW RFS.

Yours sincerely,

Martha Dotter
Team Leader, Dev. Assessment & Planning
Planning and Environment Services



BUSH FIRE SAFETY AUTHORITY

SFPP – Other Tourist Accommodation
7B Diggings Tce Thredbo NSW 2627 AUS, 765//DP1119757
RFS Reference: DA20200401001174-Original-1

Your Reference: (CNR-6080) DA 10181

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b* of the Rural Fires Act 1997.

Martha Dotter

Team Leader, Dev. Assessment & Planning Planning and Environment Services

Tuesday 21 April 2020